

October 7th, 2025

Star Motors of Ottawa – Mercedes Benz
400 Hunt Club Road
Ottawa, Ontario
Our Ref: 2302

ADDENDUM No. 5

Addendum No.5 involves changes and additions to the drawings and shall form part of the Contract documents.

Architectural - Drawings.

- 5.1. Double gate indicated on Site Plan is NIC, to be installed by owner.
- 5.2. Drawing Notes have been added to Drawing A-100
- 5.3. Extent of work indicated has been revised. Refer to drawing A-101.
- 5.4. Drawing Notes on A-501 have been edited.
- 5.5. Drawing A-901, Interior Elevations and drawing A-701, Plan Detail has been revised. Note labels added.
- 5.6. Refer to Floor Finishes Plan for location for porcelain tile PT-1 to PT-3.
- 5.7. Refer to BPA Addendum S001 and SK for locations of 152 x 152 HSS horizontal Girts and 178 x 178
- 5.8. Canopy fascia to be 1200 mm high, metal stud framing and exterior sheathing with horizontal metal siding both sides. Refer to drawing A-201.
- 5.9. Supply and install 7 U-shaped bollards in front of all Service Advisors pods, prefinished powder coat black as manufactured by MAGLIN, BISON or equal.

brian k. clark

A.R.C.H.I.T.E.C.T

End of Addendum